

MAINTENANCE INSTRUCTIONS: **BLUESEAL REFILL**

DO NOT REMOVE TRAP FOR REFILL

One 3 oz. refill will last for approx. 1500 uses.

No need to refill daily!! See interval chart to the right.




BlueSeal[®] Trap Liquid Estimated Intervals

Approximate Users per Day per urinal	Monthly 3 oz. BlueSeal [®] Refills
1 - 75*	Monthly
76 - 150*	Twice a Month
151 - 225*	Three Times a Month
226 - 300*	Weekly
* Based on a 5 day work week.	


1. Screw the *PortionAid* onto a *BlueSeal*[®] quart bottle.
2. Squeeze bottle to measure out 3 oz. of *BlueSeal*[®] into the *PortionAid*.

3. Pour *BlueSeal*[®] directly into *EcoTrap*[®] towards back of urinal.

Task Time: 20 Seconds



Incorrect Sealing (above rim)



Correct Sealing (below rim)

Cleaning Instructions (Traditional):

1. Remove any foreign objects and other debris from base of urinal bowl.
2. Use only non-abrasive cleaners and a soft sponge/mop on urinal surfaces for cleaning.
3. Use cleaner on wet sponge, cloth, or mop. Then wipe clean all surfaces of urinal, especially the lower front.
4. Dry all surfaces with a soft cloth or soft rag.
5. Maintenance Video may be viewed at: www.waterless.com

Cleaning Instructions (Nviro-Clean[™]):

1. Remove any foreign objects and other debris from base of urinal bowl.
2. Spray Nviro-Clean[™] liberally on urinal surface starting at the top and working your way down to the plastic trap insert. Cleaning should take place once or twice a day or as wash-room traffic dictates. **DO NOT WIPE OFF OR SCRUB.**
3. Do not use any other cleaners while using Enviro-Clean[™].

MAINTENANCE INSTRUCTIONS

ECOTRAP[®] EXCHANGE

REMOVE OR EXCHANGE EcoTrap[®] ONLY WHEN NEEDED, i.e. slow urine flow or pooling. The table below shows approximate intervals.

1. Have the X-Traptor[®] tool, new EcoTrap[®], a plastic bag and a deodorizer ready and on hand.
2. Insert X-Traptor[®] into trap slots and engage on knobs.
3. While slowly pulling up, wiggle tool side to side to loosen EcoTrap[®].
DO NOT PULL STRAIGHT UP! Once the EcoTrap[®] is removed, spray some deodorizer into the drain.
4. With EcoTrap[®] still on X-Traptor[®], pour liquid contents into the open drain hole of urinal.
5. Deposit used EcoTrap[®] in plastic bag. Disengage and remove X-Traptor[®].
6. Seal the plastic bag and discard in locally appropriate manner.
7. Loosen any sediment accumulation in drain hole with any long object.
8. Pour a full bucket, approx. 5 gallons, of preferably hot water into drain hole of urinal to flush sediments from waste line before inserting new EcoTrap[®].
9. Take new EcoTrap[®] and fill with water under faucet in sink. Then set EcoTrap[®] insert into trapway. **Push EcoTrap[®] down, below rim of trapway.**
10. **Add 3 oz. of BlueSeal[®]. Done!**

TASK TIME: 3-4 Minutes

EcoTrap[®] Replacement Estimated Intervals

Approximate Users per Day per urinal	EcoTrap [®] Exchange
1 - 30*	Once a Year
31 - 60*	Twice a Year
61 - 90*	Three Times a Year
91 - 120*	Four Times a Year
* Based on 7000 uses per urinal and 240 days usage.	

{ Maintenance Video may be viewed online at: www.waterless.com }

